

**Drinking Water  
Quality Report  
2022**



**Laidlaw Water  
District**

Our goal is to provide you with peace of mind in the water you drink. This report provides you with the information needed to help understand how your water can affect your health. The safe Drinking Water Act was passed by congress in 1974 to protect the public health by regulating the nations drinking water. We take great pride in our professional staff who ensures that our water system goes above and beyond to provide you with the best tasting water and strictly meets the guidelines set forth by EPA. We are proud to say once again that we have met all the requirements. If you have any questions after reading this report, please feel free to contact our office 541.389.1255, or attend one of our regular scheduled meetings held at the office of Basic Books at 64619 Unit C, Bend Oregon with notification being made in advance. You can also visit the State <https://yourwater.oregon.gov/inventory.php?pwsno=01096> for more information. Scroll to the bottom to search all information.



**An Important Message from the  
Environmental Protection Agency**

The sources of (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals and human activity.

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and Herbicides**, comes from agricultural, urban storm-water runoff, and residential uses.

**Organic Chemical Contaminants**, synthetic and volatile organic chemicals are byproducts of industrial processes and petroleum production, and also from gas stations, urban storm-water runoff, and septic systems.

**Radioactive Contaminants**, Naturally occurring or the result of oil and gas production and mining activities.

Drinking water and bottled water may contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**Important Information About Water and  
Your Health**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advise about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants. **For more information call the Safe Drinking Water Hot Line 1-800-426-4791. Additional information can be found on the CDC website: [www.cdc.gov/healthywater/drinking/public/faq.html](http://www.cdc.gov/healthywater/drinking/public/faq.html).**

**Lead in Drinking Water....Are You at  
Risk?**

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Laidlaw Water District is responsible for providing high quality drinking water to your tap, we cannot control the variety of materials used in plumbing components in your home. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water to drink or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>, or [www.leadline.org](http://www.leadline.org), or by contacting Edge Analytical, drinking water testing laboratory 541-639-8425.

You can see our most recent test results in the data table below. We are required to report only those substances that were present at detectable levels. We are allowed to monitor for some contaminants less than once per year, therefore some of the data can be more than one year old. Below is the data from within the last 5 years.

Primary Standards (directly related to the safety of drinking water)						
Inorganic Contaminants	Units	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
2022 - Barium	ppm	2	2	0.029	No	Erosion of natural deposits
2022 - Chromium	ppb	100	100	4.7	No	Erosion of natural deposits
2022 - Fluoride	ppm	4	4	0.10	No	Erosion of natural deposits
2022 - Nitrate	ppm	10	10	1.18 - 1.45	No	Erosion of natural deposits
Organic Contaminates						
2022 - Di(2-Ethylhexyl) Phthalate	ppb	6	0	0.6	No	Discharge from rubber and Chemical plants
2 repeat samples were collected and absent of any Di(2-Ethylhexyl) Phthalate.						
Unregulated Contaminants						
2022 - Sodium	ppm	N/A	N/A	16.8	No	Erosion of natural deposits
Lead and Copper	Units	MCLG	AL	90 <sup>th</sup> %	Did a Violation occur ?	Likely Source
2022 - Copper	ppm	1.3	1.3	0.0410	No	Household plumbing
2022 - Lead	ppb	0	15	2.0	No	Household plumbing
Radiological Contaminants	Units	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
202 - Uranium	ppb	30	0	0 - 1.4	No	Erosion of natural deposits
Disinfection By-Products	Units	MCL	MCLG	Range/Result	Did a Violation occur ?	Likely Source
2022 - TTHM	ppb	80	N/A	3.5	No	By-Product of drinking water disinfection
2022 - Chlorine Residuals	ppm	4	4	0.03 - 0.90	No	By-Product of drinking water disinfection
Violation - Our water system received a violation for Late/non reporting between January and June 2022 for lead and copper. We are reporting the last round of lead and copper that was collected in 2022. The 6 month schedule of collection was inadvertently missed. We returned to compliance September 16, 2022						

- **AL - Action Level**, the concentration of a contaminant which if exceeded, triggers treatment or other requirements.
- **EPA - Environmental Protection Agency**, sets water quality standards and establishes methods and monitoring requirements for water utilities.
- **MCL - Maximum Contaminant Level**, the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- **MCLG - Maximum Contaminant Level Goal**, the level of a contaminant in drinking water which there is no known or expected risk to health. MCLG's allow a margin of safety.
- **PPB - Parts Per Billion**, the equivalent of one second in 32 years.
- **PPM - Parts Per Million**, the equivalent of one second in 12 days..
- **Result** - the column that shows you what level of contaminant was found in the water you drink.
- **TTHM - Total Trihalomethane**, by-product of drinking water disinfection.

**Laidlaw Water District Source Assessment**  
 An assessment of our water system has been completed by the Department of Human Services to determine susceptibility to potential sources of contamination. A copy is on file by contacting the office at 541.389.1255.



# Standards

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline at 1-800-426-4791.